

Report Of Passed And Failed Appliances
For all Sites and Locations

RSR Systems
Waterside House
Falmouth Road
Penryn
Cornwall
TR10 8BD

RSR

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA	
BUILDING 1 - ROOM 1												
3KW CLS2 DIMPLEX	AP0024	19/05/04	P	S	S	>200 P	1.01 P	0.13 P	S	S	S	
3KW CLS2 DIMPLEX	AP0025	19/05/04	P	S	S	>200 P	1.99 P	0.18 P	S	S	S	
3KW HEATER	AP0023	19/05/04	P	S	>19.99 F	S	S	S	S	S	S	
EXT LEAD	AP0028	19/05/04	P	F	0.06 P	>200 P	S	S	S	S	S	
EXT LEAD	AP0030	19/05/04	P	F	0.06 P	>200 P	S	S	S	S	S	
EXT LEAD	AP0029	19/05/04	P	F	0.06 P	>200 P	S	S	S	S	S	
HOOVER	AP0020	19/05/04	P	S	S	>200 P	1.29 P	0.16 P	S	S	S	
HP PDA ADAPTER	AP0017	19/05/04	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
IRON	AP0012	19/05/04	P	S	0.07 P	>200 P	1.38 P	0.18 P	S	S	S	
IRON	AP008	19/05/04	P	S	0.07 P	>200 P	S	S	S	S	S	
IRON	AP004	19/05/04	P	S	0.07 P	>200 P	1.37 P	0.19 P	S	S	S	
IRON	AP003	19/05/04	P	S	0.07 P	>200 P	1.37 P	0.19 P	S	S	S	
IRON	AP009	19/05/04	P	S	0.15 P	>200 P	1.38 P	0.18 P	S	S	S	
IRON	AP0011	19/05/04	P	S	0.07 P	>200 P	<0.05 P	<0.10 P	S	S	S	
IRON	AP0010	19/05/04	P	S	0.14 P	>200 P	1.39 P	0.18 P	S	S	S	
KENWOOD CHEFFETTE	AP0022	19/05/04	P	S	S	>200 P	0.20 P	<0.10 P	S	S	S	
KENWOOD CHEFFETTE	AP0021	19/05/04	P	S	S	>200 P	0.22 P	<0.10 P	S	S	S	
KETTLE	AP0014	19/05/04	P	S	0.03 P	>200 P	2.10 P	0.18 P	S	S	S	
KETTLE	AP0013	19/05/04	P	S	0.04 P	>200 P	2.10 P	0.18 P	S	S	S	
LAMP CLS2	AP0018	19/05/04	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
LAMP ON CLS2	AP0019	19/05/04	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
NOKIA ADAPTER	AP0016	19/05/04	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
PHILIPS ADAPTER	AP0015	19/05/04	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
TOASTER	AP007	19/05/04	P	S	0.04 P	>200 P	S	S	S	S	S	
TOASTER	AP006	19/05/04	P	S	0.09 P	>200 P	S	S	S	S	S	
TOASTER	AP0026	19/05/04	P	S	0.04 P	S	1.01 P	0.13 P	S	S	S	
TOASTER	AP005	19/05/04	P	S	0.08 P	>200 P	S	S	S	S	S	
VIS FAIL	AP0027	19/05/04	F	S	S	S	S	S	S	S	S	
Total Appliances:											28	
BUILDING 1 - ROOM 2												
EXT LEAD 5	AP0034	19/05/04	P	F	0.31 P	>200 P	S	S	S	S	S	
EXT LEAD DOUBLE	AP0031	19/05/04	P	F	0.17 P	>200 P	S	S	S	S	S	
EXT LEAD LONG	AP0035	19/05/04	P	F	0.44 P	>200 P	S	S	S	S	S	
EXT LEAD QUAD	AP0033	19/05/04	P	F	0.26 P	>200 P	S	S	S	S	S	
EXT LEAD TRIPLE	AP0032	19/05/04	P	F	0.21 P	>200 P	S	S	S	S	S	
Total Appliances:											5	
BUILDING 4 - ROOM 1C												
AMPLIFIER	AP0042	30/06/02	P	S	0.29 P	>200 P	S	S	S	<0.10 P	S	
AMPLIFIER ALPHA	AP0043	30/06/02	P	S	0.26 P	>200 P	S	S	S	<0.10 P	S	
EXT LEAD	AP0044	30/06/02	P	F	0.05 P	>200 P	S	S	S	S	S	
IT EQUIPMENT	AP0041	30/06/02	P	S	0.28 P	>200 P	S	S	S	<0.10 P	S	
IT EQUIPMENT	AP0038	30/06/02	P	S	S	>200 P	S	S	S	<0.10 P	S	
IT EQUIPMENT	AP0040	30/06/02	P	S	0.67 F	>200 P	S	S	S	<0.10 P	S	
LAMP	AP0036	19/05/04	P	S	0.12 F	>200 P	S	S	S	S	S	
LAMP 115	AP0037	30/06/02	P	S	S	>200 P	<0.05 P	<0.10 P	S	S	S	
Total Appliances:											8	
BUILDING 4 - ROOM 2												
EXT LEAD	AP0045	30/06/02	P	F	0.05 P	>200 P	S	S	S	S	S	
EXT LEAD	AP0046	30/06/02	P	F	0.05 P	>200 P	S	S	S	S	S	
Total Appliances:											2	
Total Appliances For Report:											43	